203020022

Water Well Log

Property owner's name and address

Teslin Health Centre



Well site address

Teslin, Y.T.

Sketch map of well location in the box above

Formation log	colour	hardness	from	to
Rocks + silt			0	6
sandy silt			6	28
boulder			28	30
silty gravel			30	42
bouldery gravel			42	55
wet silt			55	87
fine gravel			87	108

Well depth 108'

Datum point ground

Use Domestic ___ Industrial ___

Municipal ___ Monitoring ___

Other ✓

Method of drilling

Cable tool ___ Air rotary ✓

Other ___

Casing type steel ✓

welded ✓ Drill Shoe ✓

shoe ID 4½"

Hole diameter

5" to 108'

Screen None

Development method/duration

Air 3 hrs

Static water level 34'

Specific capacity 50± gpm

Pump

Other information

Whitewater Resources

Box 33912

Whitehorse, YT. Y1A 5X5

1-(867) 667-6195

Driller H.R. Kneller

Date completed

Oct 11/99