

Date: Aug 12/04  
Well Owner: John + Shannon Berryman  
Address: Box 11238  
White, Yukon Y1A 6N4  
Phone: \_\_\_\_\_ Fax: \_\_\_\_\_

Contractor: \_\_\_\_\_  
Address: \_\_\_\_\_  
Phone: \_\_\_\_\_ Fax: \_\_\_\_\_  
Driller: Ren Toppo

**General Information**

Well Location:  At owners address  Other  
Lot 1101 Cowley Road  
Water Quality:  Good  Poor, why \_\_\_\_\_

Water Analysis:  chemical  Biological  none

Comments: \_\_\_\_\_  
Taste: taste good

Water use:  domestic  Stock  Garden  
 Irrigation  Heat pump  Industry  
 Community supply; number of connections \_\_\_\_\_  
 Other \_\_\_\_\_

Aquifer:  Rock  Sand and gravel

Well Capacity  
Capacity:  dry hole  Inadequate  
 Satisfactory for proposed use

Capacity test:  Bail test  Air lift  Pump test  
Length of test 2 hrs minutes Rate: 4 gal/min  
Water level at start: 34 ft  
Drawdown at end: 52.6 ft  
Estimated well capacity: 4 gal/min  
Was a water sample taken at end of test?  Yes  No

**Final well completion**

Cover on casing  Welded plate  Pitless adaptor  
 Aluminium cover  Well seal

Casing:  above ground  In pit  In old dug well

Is casing sealed?  Yes  No  
If Yes, describe: \_\_\_\_\_

Is site protected from obvious hazards, ie. poor drainage, grazing animals, buried fuel tanks, etc.  Yes  No  
If no, what can be done? \_\_\_\_\_

If well location cannot be described from a road address, please sketch approximate location on reverse side of file copy of well record or attach separate sheet.

Well Log		Metres <input type="checkbox"/>	Feet <input checked="" type="checkbox"/>
From	To	Description	
0	38	sandy clay	
38	54	glacial til	
54		wet fine sand	

\* If drilling is in rock, note depth of fractures which make water.

**Well Construction**

Surface Casing: Diameter \_\_\_\_\_  
Length \_\_\_\_\_ Stick up \_\_\_\_\_  
 removed  Left in place

Well Casing: Diameter 6"  
Length 61'11" Stick up 18"  
Wall thickness: .250  
Casing shoe  yes  no

Completion:  well screen  slotted pipe  
 open end  other

Well screen:  stainless  galvanized steel  
 plastic  
from 59'10" to 64'4" slot width 8 slot  
from \_\_\_\_\_ to \_\_\_\_\_ slot width \_\_\_\_\_

Design based on:  sieve analysis  
 estimated slot size

Other screen data: \_\_\_\_\_

Development method:  surge  bail  air  
 water jet  pump  other \_\_\_\_\_

Static water level below ground: 34'  
 flowing Rate: \_\_\_\_\_