WELL AND PUMP DATA

Location of Well 8 Miles Wolf Creek Sub

County

Township

Township Number | Range Number | Section No. | Fraction

Property owner's name and address Bob Borrman 668-2521 Whitehorse, YT

204110259

Street Address and City or Distance and Direction from Road Intersections

Show exact location of well in section grid with an "x" **Sketch map of well location**

N
S
1 mile

Addition Name

Block Number

Lot Number

Well depth 55'

Datum point from which all measurements are taken ground

Remarks, Elevation, Source of Data, etc.

Method of Drilling
☐ Cable tool ☐ Hollow rod ☐ Driven ☐ Dug
☐ Direct rotary ☐ Air rotary ☐ Bucket auger ☐ ____
☐ Reverse rotary ☐ Jetted ☐ Flight auger

Use
☐ Domestic ☐ Public supply ☐ Industrial ☐ ____
☐ Irrigation ☐ Municipal ☐ Commercial
☐ Test Well ☐ Heating or cooling ☐ Monitoring

Casing Type
☐ Steel ☐ Threaded Height above/below surface ____
☐ Galv. ☐ Welded
☐ PVC ☐ Solvent Drive shoe? ☐ Yes ☐ No
☐ SS welded 4½" ID

5 in	to 26 ft	Wgt	lb/ft	Sch. No.		in	diam
5 in	to 55 ft	Wgt	lb/ft	Sch. No.		in	
in	to ft	Wgt	lb/ft	Sch. No.		in	

Borehole data

Formation Log	Color	Hardness	From	To
Existing 6" well			0	30
Boulders (basalt + volcanic)			26	55
Telescoped with 5" casing				

Intake Portion of Well
Screen type None open hole from ____ ft to ____
Manufacturer
Material Dia
Fittings Length
Set between ____ ft and ____ ft Slot
____ ft and ____ ft Slot
____ ft and ____ ft Slot
Method of installation

Filter Pack
Source Gradation
Method of installation Composition
Volume used Depth to top of p

Grout
Used? ☐ Yes ☐ No Volume used
☐ Neat Cement ☐ Bentonite ☐
Method of installation
Depth from ft to
from ft to

Development
Method Air Duration 2½ hrs
Dates Sand content after hrs
Chemicals used

Static Water Level
30 ft ☐ below ☐ above grade
Date measured

Pumping Water Level
ft ☐ below ☐ above grade Date
After hrs pumping at

Specific Capacity 5± gpm/ft of drawdown at
Date Apr 14/99

Pump
Date installed Type
Manufacturer Model No.
HP Volts Capacity
Depth of pump intake setting No. of stages
☐ Oil ☐ Water lubrication Power source
Material of drop pipe bowls
shafting impellers Bowl dia
Column pipe dia Length Modifications

Well Head Completion
☐ Pitless adaptor ☐ Basement offset Distance above grade

Nearest Sources of Possible Contamination
ft Direction Type
Well disinfected upon completion? ☐ Yes ☐ No

Geophysical Logs Run

Contractor Name and Address WHITEWATER RESOURCES
BOX 33012
WHITEHORSE, Y.T. Y1A 5Y5

Name of Driller H. ROGER KIELLER

PHONE (403) 667-6195

Water Quality
Sample taken? ☐ Yes ☐ No
Where analyzed

Apr 14/99