Well Log

Date: Oct 17/07

Well Owner: Craig & Barb Hansen

Address: Takhini Road Subdivision Lot 110

Phone: _____ Fax: _____

General Information

Well Location: ☑ At owners address ☐ Other

Water Quality: ☐ Good ☐ Poor, why _____

Water Analysis: ☑ chemical ☑ Biological ☐ none

Comments: _____

Taste: _____

Water use: ☑ domestic ☐ Stock ☑ Garden

☐ Irrigation ☐ Heat pump ☐ Industry

☐ Community supply; number of connections _____

☐ Other _____

Aquifer: ☑ Rock ☐ Sand and gravel

Well Capacity

Capacity: ☐ dry hole ☐ Inadequate

☑ Satisfactory for proposed use

Capacity test: ☐ Bail test ☐ Air lift ☑ Pump test

Length of test _____ minutes Rate: 6.5 gpm

Water level at start: 85'

Drawdown at end: 92'

Estimated well capacity: _____

Was a water sample taken at end of test? ☑ Yes ☐ No

Final well completion

Cover on casing ☐ Welded plate ☑ Pitless adaptor

☐ Aluminium cover ☐ Well seal

Casing: ☑ above ground ☐ In pit ☐ In old dug well

Is casing sealed? ☐ Yes ☑ No

If Yes, describe: _____

Is site protected from obvious hazards, ie. poor drainage, grazing animals, buried fuel tanks, etc. ☑ Yes ☐ No

If no, what can be done? _____

If well location cannot be described from a road address, please sketch approximate location on reverse side of file copy of well record or attach separate sheet.

Contractor: Cathway Water Resources

Address: _____

Phone: _____ Fax: _____

Driller: Ron Towns

Well Log		Metres ☐ Feet ☐
From	To	Description
0	64'	sand + clay overburden
64	260	bedrock

* If drilling is in rock, note depth of fractures which make water.

Well Construction

Surface Casing: Diameter 8"

Length 15' Stick up _____

☑ removed ☐ Left in place

Well Casing: Diameter 6"

Length 65'6" Stick up 18"

Wall thickness: .250

Casing shoe ☑ yes ☐ no

Completion: ☐ well screen ☐ slotted pipe

☐ open end ☐ other

Well screen: ☐ stainless ☐ galvanized steel

☐ plastic

from _____ to _____ slot width _____

from _____ to _____ slot width _____

Design based on: ☐ sieve analysis

☐ estimated slot size

Other screen data: _____

Development method: ☐ surge ☐ bail ☑ air

☐ water jet ☑ pump ☐ other _____

Static water level below ground: 85'

☐ flowing Rate: _____

Cathway Water Resources, Box 21048, Whitehorse, Yukon Y1A 6P6 Phone/Fax: (867) 668-7208 Home 668-1103

Willow Printers