

204140230

Date: _____
Well Owner: Pete + Sharon Jensen
Address: Lot 1366 Km 203, Klondike Hwy
Phone: _____ Fax: _____

Contractor: Cathway Water Resources
Address: _____
Phone: _____ Fax: _____
Driller: Ron Toews

General Information

Well Location: At owners address Other
Water Quality: Good Poor, why _____

Water Analysis: chemical Biological none
Comments: _____
Taste: _____

Water use: domestic Stock Garden
 Irrigation Heat pump Industry
 Community supply; number of connections _____
 Other _____

Aquifer: Rock Sand and gravel
Well Capacity
Capacity: dry hole Inadequate

Satisfactory for proposed use
Capacity test: Bail test Air lift Pump test
Length of test 30 hrs minutes Rate: 8 gpm.
Water level at start: 25 ft
Drawdown at end: 29 ft.
Estimated well capacity: 20 gpm +
Was a water sample taken at end of test? Yes No

Final well completion

Cover on casing Welded plate Pitless adaptor
 Aluminium cover Well seal
Casing: above ground In pit In old dug well
Is casing sealed? Yes No
If Yes, describe: _____
Is site protected from obvious hazards, ie. poor drainage, grazing animals, buried fuel tanks, etc. Yes No
If no, what can be done? _____

If well location cannot be described from a road address, please sketch approximate location on reverse side of file copy of well record or attach separate sheet.

Well Log		Metres <input type="checkbox"/>	Feet <input type="checkbox"/>
From	To	Description	
0	225	clay	
225	233	silty sand	
233	248	till	
248	255	gravel. w/water	

* If drilling is in rock, note depth of fractures which make water.

Well Construction

Surface Casing: Diameter 8"
Length 15' Stick up _____
 removed Left in place

Well Casing: Diameter 6"
Length 251' Stick up 2ft
Wall thickness: .250
Casing shoe yes no

Completion: well screen slotted pipe
 open end other

Well screen: stainless galvanized steel
 plastic
from 248 to 253 slot width .018
from _____ to _____ slot width _____

Design based on: sieve analysis
 estimated slot size

Other screen data: _____

Development method: surge bail air
 water jet pump other _____

Static water level below ground: 25 ft
 flowing Rate: _____