

Well Owner: [REDACTED]  
 Address: Lot 1366 Km 203, Klondike Hwy  
 Phone: \_\_\_\_\_ Fax: \_\_\_\_\_

Contractor: Pathway Water Resources  
 Address: \_\_\_\_\_  
 Phone: \_\_\_\_\_ Fax: \_\_\_\_\_  
 Driller: Ron Toews

**General Information**

Well Location:  At owners address  Other

Water Quality:  Good  Poor, why \_\_\_\_\_

Water Analysis:  chemical  Biological  none

Comments: \_\_\_\_\_  
 Taste: \_\_\_\_\_

Water use:  domestic  Stock  Garden  
 Irrigation  Heat pump  Industry  
 Community supply; number of connections \_\_\_\_\_  
 Other \_\_\_\_\_

Aquifer:  Rock  Sand and gravel

Well Capacity

Capacity:  dry hole  Inadequate  
 Satisfactory for proposed use

Capacity test:  Bail test  Air lift  Pump test

Length of test 30 hrs minutes Rate: 8 gpm.

Water level at start: 25 ft

Drawdown at end: 29 ft.

Estimated well capacity: 20 gpm +

Was a water sample taken at end of test?  Yes  No

**Final well completion**

Cover on casing  Welded plate  Pitless adaptor

Aluminium cover  Well seal

Casing:  above ground  In pit  In old dug well

Is casing sealed?  Yes  No

If Yes, describe: \_\_\_\_\_

Is site protected from obvious hazards, ie. poor drainage, grazing animals, buried fuel tanks, etc.  Yes  No

If no, what can be done? \_\_\_\_\_

If well location cannot be described from a road address, please sketch approximate location on reverse side of file copy of well record or attach separate sheet.

Well Log		Metres <input type="checkbox"/>	Feet <input type="checkbox"/>
From	To	Description	
0	225	clay	
225	233	silty sand	
233	248	till	
248	255	gravel. w/water	
zone: 8V UTM N: 6751861 UTM E: 491765			

\* If \_\_\_\_\_ which make water.

**Well Construction**

Surface Casing: Diameter 8"  
 Length 15' Stick up \_\_\_\_\_

removed  Left in place

Well Casing: Diameter 6"

Length 251' Stick up 2 ft +

Wall thickness: .250

Casing shoe  yes  no

Completion:  well screen  slotted pipe

open end  other

Well screen:  stainless  galvanized steel

plastic

from 248 to 253 slot width 0.18

from \_\_\_\_\_ to \_\_\_\_\_ slot width \_\_\_\_\_

Design based on:  sieve analysis

estimated slot size

Other screen data: \_\_\_\_\_

Development method:  surge  bail  air

water jet  pump  other \_\_\_\_\_

Static water level below ground: 25 ft

flowing Rate: \_\_\_\_\_